WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43203
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 19106

1. OWNER Budge Brown
MAILING ADDRESS 874 East Woodward
Manteca, CA 95337

ADDRESS AT WELL LOCATION
Eagle Ranch 12241 Pioneer Way Fallon

2. LOCATION NE ¼ SE ¼ Sec. 29 T 19 N/S R 27 E Churchill County

PERMIT NO. 44284 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	14	14
Clay		14	48	34
Coarse sand		48	90	42
Clay		90	114	24
Gravel		114	120	6
Clay/coarse sand stringers		120	214	94
Cobbles/gravel		214	276	62
Clay		276	300	24

'93 DEC 10 AM 10:09 STATE ENGINEER'S OFFICE

Date started November 22, 19 93
Date completed November 25, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2500	115	6½

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
34	Inches	0	Feet	14	Feet
26	Inches	0	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+2	100
30		conductor	0	14

Perforations:
Type perforation Mill slot
Size perforation 1/8 X 2 1/2 Double Row
From 100 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 37' 1½" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed C. C. Epple (By driller performing actual drilling on site or contractor)
Date 12-8-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627