

OFFICE USE ONLY  
 Log No. 43204  
 Permit No. \_\_\_\_\_  
 Basin 8-101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Bruce Homer ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2343 Thurman Lane 5576 Riversedge  
Fallon, NV 89406 Fallon, NV 89406  
 2. LOCATION SE 1/4 SW 1/4 Sec. 28 T. 19 N. R 28 E. Churchill County  
 PERMIT NO. 08-551-35 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Brown Sand		0	30	30
Fine Brown Sand		30	43	13
Coarse & Fine Grey Sand		43	57	14
Grey Sandy Clay		57	63	6
Coarse Brown Sand		63	78	15
Fine Brown Sand		78	107	29
Grey Clay		107	114	7
Fine Gray Sand		114	125	11
Grey Sandy Clay		125	130	5
Brown Sand		130	132	2
Gray Clay		132	135	3
Coarse Brown Sand	X	135	145	10

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 145 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	140

Perforations:  
 Type perforation Well Screen  
 Size perforation .035  
 From 140 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 100  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 145 feet

9. WATER LEVEL  
 Static water level 7'10" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started 12/7, 19 93  
 Date completed 12/7, 19 93

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, INC. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Dec 13, 1993