

OFFICE USE ONLY  
 Log No. 43210  
 Permit No. \_\_\_\_\_  
 Basin. 8-102  
 NOTICE OF INTENT NO. 23473

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bruce Bates (Hy Kashenburg) ADDRESS AT WELL LOCATION 8th St + Tamarack  
 MAILING ADDRESS 1317 Jones Street Silver Springs, Nevada  
Reno, Nevada 89503  
 2. LOCATION SE 1/4 SW 1/4 Sec. 16 T. 17 N/S R. 25 E. 2 Lyon County  
 PERMIT NO. N/A 17-372-13 Stockton #2 Lot #84  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>16</u>	<u>16</u>
<u>Sand gravel</u>		<u>16</u>	<u>28</u>	<u>12</u>
<u>Clay Chert Sand</u>		<u>28</u>	<u>30</u>	<u>22</u>
<u>Beige Clay</u>		<u>30</u>	<u>80</u>	<u>30</u>
<u>Grey Clay</u>		<u>80</u>	<u>126</u>	<u>46</u>
<u>Coarse Sand, Gravel</u>	<u>126</u>	<u>139</u>	<u>139</u>	<u>13</u>

8. WELL CONSTRUCTION  
 Depth Drilled 139 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 139 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>1.88</u>	<u>+1</u>	<u>139</u>

Perforations:  
 Type perforation Multiflow  
 Size perforation 3/16 x 3 x 6 ft  
 From 1.19 feet to 139 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 139 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling, Inc Contractor  
 Address PO 599 Contractor  
SS NV, 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed Daniel Leach  
 By driller performing actual drilling on site or contractor  
 Date 12/7/93

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>6580</u>	<u>2 1/2</u>	

 Date started 12/2/93, 19\_\_\_\_  
 Date completed 12/4/93, 19\_\_\_\_

93 DEC 27 P12:25  
 RECEIVED  
 STATE ENGINEERS OFFICE