WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43218
Permit No.
Basin 8-104

NOTICE OF INTENT NO. 18102

1. OWNER Carsonite International Fac.
MAILING ADDRESS Carson City, Nv.
1301 Hot Springs Rd. - West Side

ADDRESS AT WELL LOCATION same

2. LOCATION NE ¼ SE ¼ Sec. 5 T. 15 N/S R. 20 E. Carson County

PERMIT NO. M/O 682 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other auger

6. CI-1 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silty sand w/clay		0	6.5'	6.5'
clayey sand	Yes	6.5'	7.5'	1'
silty sand w/clay		7.5'	15'	7.5'

'93 DEC 29 AM 10:26
STATE ...

Date started 6/18, 1993
Date completed 6/18, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	15 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~2~~		~~PVC Sch 40~~	~~0~~	~~15~~
~~2~~		~~Stainless Steel~~		
2		PVC Sch 40	0	4.5

Perforations:
Type perforation Factory Slot
Size perforation .010 Stainless Steel
From 4.5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 4'
Placement Method: ☐ Pumped ☑ Poured

Seal Type:
☑ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 4 feet to 15 feet

9. WATER LEVEL
Static water level 6.23 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Andresen Drilling (Contractor)
Address 1635 Belford Road (Contractor)
Reno, Nv.

Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1028

Signed [signature]
By driller performing actual drilling on site or contractor
Date 11/26/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627