WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43221
Permit No.
Basin 8-04

NOTICE OF INTENT NO. 21152

1. OWNER Carsonite International Fac. ADDRESS AT WELL LOCATION same
MAILING ADDRESS 1301 Hot Springs Rd. West
Carson City, Nv.

2. LOCATION NE ¼ SE ¼ Sec. 5 T. 15 N/S R. 20 E. Carson County
PERMIT NO. M/C 683 A (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other auger

6. CT-4 LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| sandy soil | | 0 | 2.5' | 2.5' |
| silty sandy minor clay | | 2.5' | 6' | 3.5' |
| silty sandy clay | | 6' | 7.5' | 1.5' |
| silty sandy clay | | 7.5' | 10' | 2.5' |
| silty sandy clay | | 10' | 20' | 10' |

Date started 8/4, 1993
Date completed 8/4, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | Feet | 0 Feet | 20 Feet |
| Inches | Feet | Feet | Feet |
| Inches | Feet | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | | PVC sch 40 | 0 | 5 |
| | | | | |
| | | | | |

Perforations:
Type perforation factory slot
Size perforation .020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 4'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Drilling (Contractor)
Address 1635 Belford Road (Contractor)
Reno, Nv.
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 11/26/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627