

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 43235
 Permit No. 8-1105
 Basin 8-1105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25370

1. OWNER Bill Tomerlin ADDRESS AT WELL LOCATION 3 miles South of Kingsbury grade on Foothill
 MAILING ADDRESS PO Box 1048 GARD NV 89410
 2. LOCATION SE 1/4 Sec 10 T. 12 N/S R. 19 E Douglas County
 PERMIT NO. 58765 Issued by Water Resources 19-110-57 Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil (DG)		0	10	
SAND & small rock		10	25	
SAND		25	80	
SAND & small rock	X	80	105	
SAND (course)		105	140	
ROCK		140	145	
SAND & rocks		145	180	
SAND		180	205	
SAND & CLAYS		205	235	
SAND & small rocks		235	255	

8. WELL CONSTRUCTION
 Depth Drilled 0 Feet Depth Cased 256 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 250 Feet
14 Inches 0 Feet 256 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>15165</u>	<u>.188</u>	<u>0</u>	<u>256</u>

Perforations:
 Type perforation Jhusantype 304 Stainless
 Size perforation 180 Spot Size
 From 246 feet to 234 feet
 From _____ feet to _____ feet
 From 204 feet to 171 feet
 From _____ feet to _____ feet
 From 151 feet to 118 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 256 feet to 100 feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 11-18/11-22 1993
 Date completed 12/12-18 1993

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>80-100</u>	<u>-</u>	<u>3hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Kawchack Drilling Inc Contractor
 Address Box 1359 Minden NV Contractor
 Nevada contractor's license number #021268 issued by the State Contractor's Board
 Nevada driller's license number issued by the #4195 Division of Water Resources, the on-site driller
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 12-18-93