

OFFICE USE ONLY
 Log No. 43232
 Permit No. I
 Basin. I
 NOTICE OF INTENT NO. 25367

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Josephine Uhalde ADDRESS AT WELL LOCATION East Valley Rd. GARD. NV.
 MAILING ADDRESS 267 Smith Ridge Trk. Reno NV 89502
 2. LOCATION NW 1/4 NW 1/4 Sec. 12 T. 12 N/S R. 20 E Douglas County
 PERMIT NO. 23-200-05 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & SAND		0	10	
CLAY SAND & GRAVEL		10	35	
SAND & CLAY		35	50	
ROCK SAND & GRAVEL	↑	50	70	
GRAVEL		70	100	
CLAY SAND & GRAVEL		100	145	
SAND & GRAVEL	XX	145	155	
CLAY SAND & GRAVEL	↓	155	175	
GRAVELS & CLAY	↓	175	200	

1993 DEC 13 AM 1:30
 REMOVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.5 lbs</u>	<u>.209</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation Factory Perf
 Size perforation 3" x 5/32"
 From _____ feet to _____ feet
 From 200 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 200 feet to 50 feet

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10-13 1993
 Date completed 10-19 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>BAR</u>	<u>80-90+</u>	<u>-</u>	<u>2 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Spurlock Drilling Inc. Contractor
 Address P.O. Box 1359 Primm, NV 89423 Contractor
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 10-19-93