

OFFICE USE ONLY  
 Log No. 43296  
 Permit No. 8-105  
 Basin 8-105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24465

1. OWNER Greg Painter ADDRESS AT WELL LOCATION 1421 Willow Creek Ln.  
 MAILING ADDRESS 2436 Jacks Valley Rd. Gardnerville NV. 89423  
Geona NV.  
 2. LOCATION SE 1/4 SE 1/4 Sec. 35 T 13 S R 20 E Douglas County  
 PERMIT NO. 23-540-02 Willow Creek Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Large 1/4" Gravels		2	30	28
Sandy Gravels with Clay seams		30	69	39
Clays w/ Inbedded Gravels		69	110	41
Brown Clays/Sandy		110	130	20
Broken up Gravels		130	160	30

8. WELL CONSTRUCTION  
 Depth Drilled 160' Feet Depth Cased 160' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation M:11 slot  
 Size perforation 3/2 x 3 3/4  
 From 140' feet to 160' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100' feet to 160' feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_ Contractor  
 Address \_\_\_\_\_ Contractor  
 Nevada contractor's license number 31839  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Black  
 By driller performing actual drilling on site or contractor  
 Date 11-22-93

Date started 11-19, 19 93  
 Date completed 11-21, 19 93

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>40</u>	<u>3 Hrs.</u>

'93 NOV 30 AM 10  
 STATE ENGINEERS OFFICE