

OFFICE USE ONLY
 Log No. 43217
 Permit No. _____
 Basin 8-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22280

1. OWNER WESTWINDS CONSTRUCTION ADDRESS AT WELL LOCATION 1936 BORDA
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION SW 1/4 NE 1/4 Sec. 36 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. _____ Parcel No. 23-472-59 Subdivision Name WILDFLOWER
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/GRAVEL		0	21	21
SANDY CLAY		21	36	15
CLAY		36	48	12
SANDY CLAY		48	61	13
SANDY CLAY W/GRAVEL		61	106	45
CLAY		106	109	3
BOULDER W/SAND		109	143	34
SANDY CLAY		143	209	66
CLAY		209	214	5
SANDY CLAY		214	285	71
SANDY GRAY CLAY		285	418	33
GRAY CLAY		418	423	5
SANDY GRAY CLAY		423	484	61
GRAY CLAY		484	507	23
SANDY GRAY CLAY		507	513	6
GRAY CLAY		513	562	49
SANDY GRAY CLAY		562	578	16
COARSE SAND	✓	578	597	19
GRAY CLAY		597	602	5
COARSE SAND	✓	602	615	13
SANDY GRAY CLAY		615	620	5

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
0 Feet 620 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>620</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 575 feet to 615 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 570 feet to 620 feet

9. WATER LEVEL
 Static water level 285 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

Date started 9-22, 1993
 Date completed 10-28, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION INC. Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Mooney
 By driller performing actual drilling on site of contractor
 Date 10-28-93