WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43248
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 24332

1. OWNER H+S CONSTRUCTION CO.
MAILING ADDRESS GARDNERVILLE
ADDRESS AT WELL LOCATION 1817 CAMAS CT
GARDNERVILLE

2. LOCATION SW ¼ SW ¼ Sec. 36 T. 13 (N)/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-473-29 (Parcel No.) WILDFLOWER (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/COBBLES		0	18	18
SANDY CLAY W/GRAVEL		18	74	56
SANDY CLAY		74	107	33
CLAY		107	129	22
SANDY CLAY		129	168	39
CLAY		168	175	7
SANDY CLAY		175	182	7
CLAY		182	189	7
SANDY CLAY W/GRAVEL		189	206	17
SAND & GRAVEL	✓	206	211	5
SANDY CLAY		211	212	1

'93 NOV 30 A11:04 STATE ENGINEER'S OFFICE

Date started 11-3, 19 93
Date completed 11-10, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15+	—	4

8. WELL CONSTRUCTION
Depth Drilled 212 Feet Depth Cased 212 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	212 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	212

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 192 feet to 212 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 212 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patrick J. Moore (By driller performing actual drilling on site or contractor)
Date 11-10-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627