

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25369

1. OWNER Dirk Jausoe Const. ADDRESS AT WELL LOCATION 136 Washoe Springs Rd. Minden, NV
 MAILING ADDRESS 1275 Downs, Minden, NV
 2. LOCATION NW 1/4, NW 1/4 Sec 19, T. 14, N/S R. 20 E, Douglas County
 PERMIT NO. 13-200-13 Issued by Water Resources Parcel No. _____ Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	10	
SAND (DG)		10	30	
SAND & CLAY		30	40	
SAND	X	40	60	
SAND & CLAYS		60	110	
CLAY		110	120	
SAND & CLAY		120	135	
SAND	✓	135	180	

'93 DEC 28 P. 2-24
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.5 lb</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Factory
 Size perforation 3" x 5/32"
 From _____ feet to _____ feet
 From 180 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 180 feet to 100 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 11-10, 1993
 Date completed 11-16, 1993

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	
	G.P.M.	Draw Down (Feet Below Static)	
<u>MR</u>	<u>30-40</u>	<u>—</u>	<u>2 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lawback Drilling Inc. Contractor
 Address Box 1359 Minden, NV Contractor
 Nevada contractor's license number #021268 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 4195
 Signed Michael Allen By driller performing actual drilling on site or contractor
 Date 10-16-93