WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43250
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 24326

1. OWNER HEARTHSIDE HOMES
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 2823 ESAW
MINDEN, NV

2. LOCATION SE ¼ SW ¼ Sec. 26 T. 14 (N)S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 21-240-49 (Parcel No.) JOHNSON LANE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand w cobbles		0	12	12
gravel w Sand		12	28	16
Sandy clay		28	35	7
gravel w Sandy clay		35	55	20
sandy clay		55	63	8
gravel w Sandy clay		63	95	32
sandy clay Some gravel		95	145	50
gravel w Sandy clay		145	160	15
Sandy clay Some gravel		160	182	22
Small gravel w Brn Sandy clay		182	193	11
grey Sandy clay Some gravel		193	201	8
grey Sandy clay		201	210	9
grey clay		210	212	2
course Sand Some sandy clay		212	228	16
grey clay		228	231	3
course Sand w some Sandy clay		231	247	16
grey clay		247	252	5
course Sand Some sandy clay		252	275	23
grey clay		275	280	5

Date started 11-2, 1993
Date completed 11-11, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	12+		7

8. WELL CONSTRUCTION
Depth Drilled 280' Feet Depth Cased 280' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	280' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	280

Perforations:
Type perforation Factory Slotted / Torch cut
Size perforation 3X 3/32
From 260' feet to 280' feet
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 280' feet

9. WATER LEVEL
Static water level 131' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerald W. Pinnell (By driller performing actual drilling on site or contractor)
Date 11-11-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627