WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43271
Permit No.
Basin 8-~~105~~ 179

NOTICE OF INTENT NO. 19844

1. OWNER Mike Allison
MAILING ADDRESS P.O. Box 116
Baker, Nevada 89311

ADDRESS AT WELL LOCATION 2½ miles South of Ely, Nevada

2. LOCATION NE ¼ NW ¼ Sec. 35 T. 16 N/S R. 63 E White Pine County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Coarse Gravel		2	20	18
Clay & Coarse Gravel		20	80	60
Clay & Small Gravel		80	100	20
Clay		100	110	10
Clay & Small Gravel		110	140	30
Clay		140	150	10
Clay & Small Gravel		150	270	120
Clay & Coarse Gravel		270	290	20
Clay & Small Water Gravel	X	290	330	40
Clay & Gravel		330	340	10
Clay & Small Water Gravel	X	340	370	30
Clay & Gravel		370	380	10
Gray Clay		380	402	22

'93 DEC 14 A11:41 STATE ENGINEERS OFFICE

Date started November 9, 1993
Date completed November 12, 1993

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	117	3 Hours

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 402 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	402 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	16.94	.188	0	402

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 Rows
From 290 feet to 402 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 402 feet

9. WATER LEVEL
Static water level 283 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date December 5, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627