WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43301 in Book
Permit No.
Basin 162

NOTICE OF INTENT NO. 11809

1. OWNER William Brown
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 30 T. 19-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Lot 6 Block 8 (Parcel No.) BELL VISTA UNIT 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Soft Brown Clay		4	40	36
White Clay		40	62	22
Brown Clay		62	82	20
Grey Clay	x	82	98	16
Hard Brown Shale		98	104	6
Brown Clay	x	104	116	12
Hard Shale		116	120	4
Soft Brown Clay	x	120	142	22
Light Brown Clay	x	142	166	24
Tough Light Clay		166	178	12
Brown Clay	x	178	200	22

RECEIVED
OCT 12 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Sept. 29, 1993
Date completed Oct. 1, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs.	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 Pahrump, NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg
By driller performing actual drilling on site or contractor
Date Oct-1-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627