WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43306
Permit No.
Basin

NOTICE OF INTENT NO. 12257

1. OWNER DON SPRY
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 13 LAWRENCE
PAHRUMP NV

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 20S N/S R. 52 E. NYE County
PERMIT NO. (Issued by Water Resources) 28-752-02 (Parcel No.) CHARLESTON PARK (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	10	10
CALICHIE		10	13	3
CLAY		13	28	15
CALICHIE		28	31	3
CLAY		31	41	10
CALICHIE		41	43	2
CLAY		43	50	7
CALICHIE	WB	50	52	2
CLAY		52	67	15
CALICHIE	WB	67	69	2
CLAY		69	84	15
CALICHIE	WB	84	87	3
CLAY		87	108	21
CALICHIE	WB	108	113	5
CLAY		113	116	3
CALICHIE	WB	116	119	3
CLAY		119	137	18
CALICHIE	WB	137	140	3
		140		140

Date started 10-4-93, 19
Date completed 10-8-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
NOV 12 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 8035B (Contractor)
PAHRUMP NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 10-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627