



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12262

1. OWNER ROLAND BENTON ADDRESS AT WELL LOCATION LOT 12 BRIDGER PAHRUMP NV  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SE 1/4 NE 1/4 Sec 14 T. 21 S N/S R. 53 E NYE County STARDUST  
PERMIT NO. 44-633-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	9	9
CALICHE		9	12	3
CLAY		12	19	7
CALICHE		19	23	4
CLAY		23	44	21
CALICHE		44	48	4
CLAY		48	68	20
CALICHE	WB	68	72	4
CLAY		72	89	17
CALICHE	WB	89	93	4
CLAY		93	110	17
CALICHE	WB	110	113	3
CLAY		113	126	13
CALICHE	WB	126	130	4
CLAY		130	138	8
CALICHE	WB	138	140	2
		140		140

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 140  
12.25 Inches 0 Feet 140 Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
85 18 16.9 .188 0 140  
Perforations:  
Type perforation FACTORY SAW CUT  
Size perforation 1 1/8 x 3"  
From 100 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 140 feet  
9. WATER LEVEL  
Static water level 55 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

RECEIVED

NOV 12 1993

Div. of Water Resources  
Branch Office - Las Vegas, NV

Date started 10-11-93, 19\_\_\_\_  
Date completed 10-15-93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name GREAT BASIN DRILLING CO. INC. Contractor  
Address HCR 78 BOX 80358 Contractor  
PAHRUMP NV 89041  
Nevada contractor's license number 30880 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
Signed Thomas Dan By driller performing actual drilling on site or contractor  
Date 10-23-93