


OFFICE USE ONLY  
 Log No. 43342  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12073

1. OWNER JOHN BARTLETT ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ LOT 4 GALLY ST  
 \_\_\_\_\_ PAHRUMP NV  
 2. LOCATION NE 1/4 SW 1/4 Sec 30 T. 19S N/S R. 53 E. NYE County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ 29-512-08 TUMBLEWEED EST  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	5	5
CALICHIE		5	9	4
CLAY		9	39	30
CALICHIE		39	44	5
CLAY		44	56	12
CALICHIE	WB	56	62	6
CLAY		62	86	24
CALICHIE	WB	86	88	2
CLAY		88	101	13
CALICHIE	WB	101	108	7
CLAY		108	121	13
CALICHIE	WB	121	126	5
CLAY		126	137	11
CALICHIE	WB	137	140	3
		140		140

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12.25 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85 \ 8	16.9	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1 \ 8 X 3"  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 120 feet

9. WATER LEVEL  
 Static water level 49 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. INC.  
 Contractor

Address HCR 78 BOX 80358  
PAHRUMP NV 89041  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12/20/93

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  
 Date started 12-8-93, 19\_\_\_\_\_  
 Date completed 12-11-93, 19\_\_\_\_\_

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED  
 JAN 11 1994  
 Div. of Water Resources