WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43347
Permit No. 60043
Basin 162

NOTICE OF INTENT NO. 12468

1. OWNER BERT CHRISTIE
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 6 MESQUITE AVE PAHRUMP NV

2. LOCATION SW ¼SW ¼ Sec. 34 T. 19S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 29-602-12 (Parcel No.) GERALD MARTIN ROS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	5	5
CALICHIE		5	8	3
CLAY		8	39	31
CALICHIE		39	44	5
CLAY		44	57	13
CALICHIE	WB	57	61	4
CLAY		61	86	25
CALICHIE	WB	86	88	2
CLAY		88	101	13
CALICHIE	WB	101	108	7
CLAY		108	121	13
CALICHIE	WB	121	126	5
CLAY		126	137	11
CALICHIE	WB	137	140	3
		140		140

Date started 12-8-93, 19
Date completed 12-11-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JAN 11 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 12/20/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627