WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43349
Permit No.
Basin 162

NOTICE OF INTENT NO. 13479

1. OWNER RON MURPHY
MAILING ADDRESS
ADDRESS AT WELL LOCATION IRENE ST
PAHRUMP NV

2. LOCATION SW ¼ SE ¼ Sec. 1 T 20S N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) 28-433-11 (Parcel No.) VEGAS ACRES (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	6	3
CLAY		6	11	5
CALICHIE		11	16	5
CLAY		16	34	18
CALICHIE		34	37	3
CLAY		37	46	9
CALICHIE	WB	46	53	7
CLAY		53	57	4
CALICHIE	WB	57	59	2
CLAY		59	63	4
CALICHIE	WB	63	65	2
CLAY		65	71	6
CALICHIE	WB	71	74	3
CLAY		74	87	13
CALICHIE	WB	87	91	4
CLAY		91	95	4
CALICHIE	WB	95	97	2
CLAY		97	107	10
CALICHIE	WB	107	111	4
CLAY		111	116	5
CALICHIE	WB	116	120	4
		120		120

Date started 12-8-93, 19
Date completed 12-11-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
DEC 28 1993
Div. of Water Resources
Branch Office • Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	120

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout X
Gravel Packed: ☐ Yes X ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 12/21/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627