WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43351
Permit No.
Basin 162

NOTICE OF INTENT NO. 12387

1. OWNER ED DUFFIELD
MAILING ADDRESS HCR 73 BOX 28350
PAHRUMP, NEVADA 89041

ADDRESS AT WELL LOCATION
RAND ROAD PARAUMP NV.

2. LOCATION S-E ¼ S-E ¼ Sec. ONE T. 20 S N/S R. 52 E E. NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. VEGAS ACRES UNIT ONE (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SOIL		0	8	8
GREY CLAY		8	41	33
CALICHE		41	44	3
GREY CLAY	XX	44	65	21
BROWN CLAY	XX	65	140	75

RECEIVED
JAN 19 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started JANUARY 11 1994, 1994
Date completed JANUARY 14, 1994

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	4	30 min.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation FACTORY
Size perforation 3x16 x 4 inch
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LARRY'S WATER WELL SERVICE (Contractor)
Address PO. BOX 3392 PAHRUMP NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry H Perkins (By driller performing actual drilling on site or contractor)
Date january 14 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627