WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43363
Permit No.
Basin 162

NOTICE OF INTENT NO. 12390

1. OWNER JOSE BELLVER
MAILING ADDRESS 3004 SERENE AVE. HENDERSON NEV.
ADDRESS AT WELL LOCATION 125 DONNOR PAHRUMP NV.

2. LOCATION SE ¼ NW ¼ Sec 13 T 20S N/S R 52 E E NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. CHARLESTON PARK RANCHOS (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[x] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD BROWN CLAY		0	8	8
GREY CLAY		8	40	32
CALICHE		40	43	3
brown clay		43	80	37
grey clay		80	86	6
BROWN CLAY		86	140	54

RECEIVED
JAN 19 1994
Div. of Water Resources
Branch Office - Las Vegas, Nv

Date started JANUARY 14 1994, 19
Date completed JANUARY 17 1994, 19

7. WELL TEST DATA
TEST METHOD: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-	4	30 min.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	Feet 0	Feet 140
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation FACTORY
Size perforation 3 x16 x4
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [x] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LARRY:S WATER WELL SERVICE (Contractor)
Address PO. BOX 3392 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry H Jenkins (By driller performing actual drilling on site or contractor)
Date JANUARY 17 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627