

OFFICE USE ONLY
 Log No. 43370
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 12067

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER king's Land ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ RANCHO ST
 _____ PAHRUMP NV
 2. LOCATION SW 1/4 SE 1/4 Sec 23 T 20S N/S R 52 E NYE County _____
 PERMIT NO. 28-822-16 CHARLESTON PARK
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	3	3
CALICHIE		3	5	2
CLAY		5	14	9
CALICHIE		14	17	3
CLAY		17	29	12
CALICHIE		29	31	2
CLAY		31	55	24
CALICHIE	WB	55	58	3
CLAY		58	67	9
CALICHIE	WB	67	69	2
CLAY		69	81	12
CALICHIE	WB	81	83	2
CLAY		83	98	15
CALICHIE	WB	98	101	3
CLAY		101	110	9
CALICHIE	WB	110	118	8
CLAY		118	127	9
CALICHIE	WB	127	129	2
CLAY		129	134	5
CALICHIE	WB	134	136	2
CLAY		136	140	4
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140 Feet
 12.25 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1 1/8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. INC.
 Contractor

Address HCR 78 BOX 80358
PAHRUMP NV 89041
 Contractor

Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 12/1/93

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Div. of Water Resources
 Branch Office - Las Vegas, NV

RECEIVED
 DEC 28 1993