WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43371
Permit No.
Basin 162

NOTICE OF INTENT NO. 12472.

1. OWNER Kings land Dev.
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lawrence Street.

2. LOCATION SW ¼ SE ¼ Sec. 23 T. 20S N/S R. 52 E. Nye. County
PERMIT NO. (Issued by Water Resources) Parcel No. Charleston Park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay.		0	8	8
Calichie.		8	10	2
Clay.		10	21	11
Calichie.		21	23	2
Clay.		23	32	9
Calichie.		32	37	5
Clay.		37	50	13
Calichie.		50	57	7
Clay.		57	68	11
Calichie.		68	71	3
Clay.		71	77	6
Calichie.		77	79	2
Clay.		79	89	10
Calichie.		89	91	2
Clay.		91	114	23
Calichie.		114	116	2
Clay.		116	123	7
Calichie.		123	127	4
Clay.		127	130	3
Calichie.		130	134	4
Clay.		134	137	3
Calichie.		137	140	3

Date started 12-6, 1993
Date completed 12-8, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
DEC 28 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140. Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.97	.188	-1	140

Perforations:
Type perforation SAW.
Size perforation 7/8 inch by 3 inch.
From 120 feet to 140. feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 48. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 8635 8 (Contractor)
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30680.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed (By driller performing actual drilling on site or contractor)
Date 12-20-93.

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627