WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43372
Permit No.
Basin

NOTICE OF INTENT NO. 12467

1. OWNER LOU AZZARA
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 2 WINDY
PAHRUMP NV

2. LOCATION SE ¼ NW ¼ Sec. 24 T. 20S N/S R. 52 E. NYE County
PERMIT NO. (Issued by Water Resources) 28-513-01 (Parcel No.) ROCK-N-HORSE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	9	9
CALICHIE		9	12	3
CLAY		12	17	5
CALICHIE		17	20	3
CLAY		20	28	8
CALICHIE		28	31	3
CLAY		31	47	16
CALICHIE	WB	47	49	2
CLAY		49	61	12
CALICHIE	WB	61	63	2
CLAY		63	73	10
CALICHIE	WB	73	80	7
CLAY		80	98	18
CALICHIE	WB	98	101	3
CLAY		101	112	11
CALICHIE	WB	112	114	2
CLAY		114	123	9
CALICHIE	WB	123	125	2
CLAY		125	131	6
CALICHIE	WB	131	134	3
CLAY		134	138	4
CALICHIE	WB	138	140	2
		140		140

Date started 11-4-93, 19
Date completed 11-6-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
DEC 28 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12.25	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on site or contractor)
Date 11-20-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627