


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 43373  
 Permit No. \_\_\_\_\_  
 Basin. 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12068

1. OWNER ED BURGETT ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ PARCEL 65  
 \_\_\_\_\_ PAHRUMP NV 89041  
 2. LOCATION NW 1/4 SW 1/4 Sec 2 T.20S N/S R 53 E NYE County \_\_\_\_\_  
 PERMIT NO. 35-033-34 GREEN VALLEY EST  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material        | Water Strata | From | To  | Thick-ness |
|-----------------|--------------|------|-----|------------|
| CLAY            |              | 0    | 25  | 25         |
| CLAY & GRAVEL   |              | 25   | 140 | 115        |
| GRAVEL          |              | 140  | 147 | 7          |
| CEMENTED GRAVEL | WB           | 147  | 175 | 28         |
| LOOSE GRAVEL    | WB           | 175  | 190 | 15         |
|                 |              | 190  |     | 190        |

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12.25 Inches 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8.5                | 16.9                | .188                    | 0           | 190       |

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1 1/8 x 3"  
 From 170 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 190 feet

RECEIVED  
 JAN 11 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11-23-93, 19\_\_\_\_  
 Date completed 11-23-93, 19\_\_\_\_

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

RECEIVED  
 JAN 11 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO., INC. Contractor  
 Address HCR 70 BOX 80358 Contractor  
PAHRUMP NV 89041  
 Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 12/20/93