WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43395
Permit No. Copy
Basin

NOTICE OF INTENT NO. 12349

1. OWNER Paul Moore
MAILING ADDRESS Maser RD # 6 PUNU 89041
ADDRESS AT WELL LOCATION 1350 W. Chinn PUNU 89041

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 20 N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 40-253-15 (Parcel No.) Cal Ocala (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 5 | 5 |
| Cobble | 110 | 5 | 125 | 120 |

RECEIVED
JAN 17 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-14, 1993
Date completed 11-19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 60 | 25 | 3.0 |

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12¼ Inches | 0 Feet | 120 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 19.7 | .188 | 0 | 125 |

Perforations:
Type perforation Torch
Size perforation 1/16" X 4"
From 60 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 125 feet

9. WATER LEVEL
Static water level 69 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce Robinson (Contractor)
Address Po Box 8307 (Contractor)
PVNV 89041
Nevada contractor's license number issued by the State Contractor's Board 15972
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
Signed Bruce Robinson (By driller performing actual drilling on site or contractor)
Date 11-19-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627