WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43415
Permit No.
Basin

NOTICE OF INTENT NO. 12388

1. OWNER GEORGE BEHAR
MAILING ADDRESS PO, BOX 72668
PAHRUMP NV, 89041

ADDRESS AT WELL LOCATION
6640 S CAPRICORN
PARUMP NV. 89041

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 21S N/S R. 54 E. nye County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SOIL		0	8	8
BROWN CLAY		8	21	13
CALICHE		21	23	2
BROWN CLAY		23	53	30
GREY CLAY @ GRAVEL		53	57	4
GREY CLAY		57	90	33
CALICHIE		90	92	2
GREY CLAY		92	134	42
BROWN CLAY & GRAVEL		134	140	6

RECEIVED
DEC 16 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started DEC 10, 1993
Date completed DEC 14, 1993

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	7	½ hour

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	140

Perforations:
Type perforation FACTORY
Size perforation 3x16 x4
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 59 ft. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LARRY,s WATER WELL SERVICE (Contractor)
Address PO. BOX 3392 PAHRUMP NV.89041 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry H Fuller (By driller performing actual drilling on site or contractor)
Date DEC. 14 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627