WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43431
Permit No.
Basin 212

NOTICE OF INTENT NO. 11692

1. OWNER James Blaine
MAILING ADDRESS 2300 Rock Springs #2124
Las Vegas, NV 89128

ADDRESS AT WELL LOCATION
~~XXXXX~~ 7260 Boyd

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 19 ~~N~~ S R. 60 E. Clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White clay		0	140	140
Some grav. with clay		140	160	20
White clay		160	220	60
Grav. mixed withwhite clay		220	240	20
Brown clay		240	260	20
White clay		260	340	80
Gravel & clay		340	380	40
White clay		380	440	60
White clay & gravel		440	455	15

RECEIVED
NOV 03 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started September 18, 1993
Date completed September 24, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 455 Feet Depth Cased 453 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	455 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	15.64	.188	±1	453

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½ 8 rows
From ~~353~~ 333 feet to ~~453~~ 433 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 200'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200 feet to 455 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC.
Contractor
Address 4185 West Harmon
Contractor
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489

Signed Richard K. Thompson
By driller performing actual drilling on site or contractor

Date October 20, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (01-627)