WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43437
Permit No. 57464
Basin 212

NOTICE OF INTENT NO. 10800

1. OWNER Greg Trent
MAILING ADDRESS 4021 Leon
No. LV Nev. 89130

ADDRESS OF WELL LOCATION
N/A

2. LOCATION NW ¼ NW ¼ Sec 19 T 19 N/S R 60 E Clark County

PERMIT NO. 57464 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	10	
Cemented Gravel		10	18	
Gravel		18	130	
Boulders		130	160	
Cemented Gravel		160	225	
Gravel & Clay		225	495	
Gravel & Water	xx	495	510	
Cemented Gravel		510	585	
Gravel & Water	xx	585	605	
Cemented Gravel		605	635	
Gravel & Water	xx	635	650	

RECEIVED
OCT 14 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9/30/93, 19
Date completed 10/5/93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0 Feet	70 Feet
10 5/8" Inches	70 Feet	650 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	650

Perforations:
Type perforation Factory
Size perforation 3/16" x 8 row
From 610 feet to 630 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 500 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nevada 89129

Nevada contractor's license number issued by the State Contractor's Board 10052
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date Oct 7, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627