WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43444
Permit No.
Basin 212

NOTICE OF INTENT NO. 11698

1. OWNER Larry & Vivian Jackson
MAILING ADDRESS 6121 No. Tenaya Way
Las Vegas, NV 89130

ADDRESS AT WELL LOCATION
Same

2. LOCATION SE ¼ NW ¼ Sec. 27 T. 19 ☒ N/S R. 60 E. Clark County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	40	40
White sandy clay		40	180	140
Brown sandy clay		180	260	80
Br. sandy clay, some gravel		260	320	60
Gravel stringers & br. clay		320	380	60
Brown sandy clay		380	420	20

RECEIVED
DEC 10 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started November 15, 1993
Date completed December 3, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	420 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	15.64	.188	+1	420

Perforations:
Type perforation Mill slots
Size perforation 1/8" x 2½" 8 rows
From 339 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 420 feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon (Contractor)
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489

Signed Richard K. Thompson
By driller performing actual drilling on site or contractor

Date December 8, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627