WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.140

OFFICE USE ONLY
Log No. 43482
Permit No.
Basin

NOTICE OF INTENT NO. 10811

1. OWNER Lloyd Smith #2
MAILING ADDRESS
ADDRESS AT WELL LOCATION N/A

2. LOCATION SE ¼ NE ¼ Sec. 14 T 22 N/S R 59 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay Gravel | | 0 | 50 | |
| Hard Limestone | | 50 | 68 | |
| Grey Limestone | | 68 | 150 | |
| Limestone & Water | xx | 150 | 155 | |
| Reddish Limestone | | 155 | 260 | |
| Grey Limestone | | 260 | 290 | |
| Cream Limestone | | 290 | 300 | |
| Grey Limestone | | 300 | 460 | |
| Reddish Limestone | | 460 | 470 | |
| Grey Limestone | | 470 | 550 | |
| Limestone & Water | xx | 550 | 555 | |
| Grey Limestone | | 555 | 606 | |
| Limestone & Water | xx | 606 | 656 | |

RECEIVED
JAN 11 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 7/1/93, 19
Date completed 8/13/93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 656 Feet Depth Cased 656 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 12 1/4" | 0 | 55 |
| 9 7/8" | 55 | 656 |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8" | 16.94 | .188 | +2 | 430 |
| 6 5/8" | 12.92 | .188 | 406 | 656 |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row &3/16 x 6 row 6"
From 390 feet to 410 feet
From 556 feet to 576 feet
From 616 feet to 636 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 475 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista (Contractor)
Las Vegas, Nev. 89129
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 8-24-93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627