WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43489
Permit No.
Basin 212

I

NOTICE OF INTENT NO. 12197

1. OWNER STEVE WADKINS
MAILING ADDRESS
ADDRESS AT WELL LOCATION RUSH + EDMUND

2. LOCATION SE ¼ SE ¼ Sec. 25 T 22 N/S R 60 E CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY + GRAVEL		0	30	30
CMT. GRAVEL		30	40	10
CMT. GRAVEL W/ STRKS. SANDSTONE		40	140	100
SANDSTONE W/ STRKS CMT GRAVEL		140	200	60
SANDSTONE W/ STRKS BROWN CLAY	350	200	330	130
SANDSTONE W/ STRKS CMT GRAVEL		330	400	70
CMT GRAVEL W/ STRKS SANDSTONE		400	430	30

RECEIVED
DEC 15 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-7, 1993
Date completed 12-11, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 430 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	60 Feet
9 7/8 Inches	60 Feet	430 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	430

Perforations:
Type perforation FACTORY SAW
Size perforation 1/8 x 2 1/2
From 400 feet to 430 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 430 feet

9. WATER LEVEL
Static water level 273 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING
Contractor
Address 6475 GARY AVE
Contractor
LAS VEGAS, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed Pyndall Couch
By driller performing actual drilling on site or contractor
Date 12/13/93

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627