

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

43498
 OFFICE USE ONLY
 Log No. 43498
 Permit No. 212
 Basin. 212

NOTICE OF INTENT NO. 10962

1. OWNER Clarence Wanta ADDRESS AT WELL LOCATION W. Dale
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NW 1/4 Sec 9 T. 23 N. R. 61 E Clark County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Boulders & Clay (mineral)	X 92d	3	460	457
Cobbles & Clay		460	555	95
Red Clay		555	565	10
Consolidated Gravels		565	620	55
Limestone	X	620	645	25

8. WELL CONSTRUCTION
 Depth Drilled 645 Feet Depth Cased 645 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 645 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>71</u>	<u>645</u>

Perforations:
 Type perforation Socket
 Size perforation 1 1/4" x 8"
 From 585 feet to 645 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout
 Concrete Grout
 Depth of Seal 50 ft
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 645 feet

RECEIVED
 SEP 24 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 9-7- 1993
 Date completed 9-13 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50 to 60</u>	<u>3 ft</u>	<u>for air lift</u>

9. WATER LEVEL
 Static water level 360 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality OK

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Mitchell Enterprises
 Address 630 Ritting
 LU NO 89124
 Nevada contractor's license number issued by the State Contractor's Board 27030
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
 Signed Nolan Mitchell
 By driller performing actual drilling on site or contractor
 Date 9-15-93