

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 43510
 Permit No. 9-102
 Basin. 9-102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22801

1. OWNER JIM ROEBER ADDRESS AT WELL LOCATION 144 Davis Lane
 MAILING ADDRESS Wellington, Nev
 2. LOCATION NW 1/4 SW 1/4 Sec 34 T. 11 S. R. 23 E. LYON County
 PERMIT NO. None Issued by Water Resources Parcel No. 10-361-06 Subdivision Name None

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	10	
SANDY BRN CLAY w/GRNLS		10	40	
DC w/BRN CLAY		40	60	
SM. SLD. w/SANDY BRN CLAY		60	80	
DE w/BRN SANDY CLAY		80	180	
DC w/SANDY CLAY		180	220	
red dirt started to gravel + sand		220	247	

94 JAN 31 P 226
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 247 Feet Depth Cased 247 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6" To 247 Feet
 Inches..... Feet..... Feet
 Inches..... Feet..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>9 7/8</u>		<u>1.88</u>	<u>0</u>	<u>247</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3/32" x 3
 From 207 feet to 247 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 247 feet

9. WATER LEVEL
 Static water level 173 feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature Cold °F Quality good

Date started 10-11 1993
 Date completed 12-20 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>180</u>	<u>5 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address P.O. BOX 92 Contractor
SMITH, NV
 Nevada contractor's license number 32166 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller By driller performing actual drilling on site or contractor
 Date Jan 21 1994