WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43512
Permit No.
Basin 09-107

NOTICE OF INTENT NO. 18960

1. OWNER Roy LERG
MAILING ADDRESS PO BOX 22
SMITH NV 89430

ADDRESS AT WELL LOCATION
HUDSON WAY
SMITH NV

2. LOCATION E ¼ SW ¼ Sec. 15 T. 11 N/S R. 24 E. LYON County

PERMIT NO. (Issued by Water Resources) | Parcel No. 10451 03 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	9	
SAND		9	20	
SANDY BROWN CLAY		20	40	
" "		40	55	
BLUE CLAY		55	80	
SOME GRAVEL W/ BLUE CLAY		80	100	
" "	W/B	100	140	
BROWN CLAY W SAND	W/B	140	165	
SOME RICK	W/B	165	155	
SMALL GRAVELS W/ BROWN CLAY	W/B	155	240	
SAND		240	260	

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
28		6 HR

Date started 1 2, 1994
Date completed 1/5/, 1994

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	260

Perforations:
Type perforation FACTORY T.C.
Size perforation 3/32 x 3
From 260 feet to 240 feet T.C.
From 240 feet to 200 FACTORY feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 190 feet below land surface
~~Artesian flow~~ G.P.M. 28 P.S.I.
Water temperature 68 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER (Contractor)
Address PO BOX 92 (Contractor)
SMITH NV 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718 T
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1 6 94

FEB 9 AM 8:28 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627