

OFFICE USE ONLY
 Log No. 43513
 Permit No. 8-1091
 Basin 8-1091

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24277

1. OWNER DAVE MOLINE ADDRESS AT WELL LOCATION 587 LEE ALLEN GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE

2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 12 N. R. 19 E. DOUGLAS County
 PERMIT NO. 19-410-06 Parcel No. FOOTHILL Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & boulders</u>		<u>0</u>	<u>23</u>	<u>23</u>
<u>Sand coarse</u>		<u>23</u>	<u>39</u>	<u>16</u>
<u>Boulders & sandy clay</u>		<u>39</u>	<u>102</u>	<u>63</u>
<u>DG</u>	<u>X</u>	<u>102</u>	<u>112</u>	<u>10</u>
<u>DG w sandy clay</u>		<u>112</u>	<u>129</u>	<u>17</u>
<u>DG w Short Sandy clay</u>		<u>129</u>	<u>150</u>	<u>21</u>

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Factory
 Size perforation 3 X 3/32
 From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 150 feet

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDD CO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald P. Rhinold
 By driller performing actual drilling on site or contractor
 Date 12-10-93

Date started 11-29, 1993
 Date completed 12-7, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>20</u>		<u>4.15</u>

94 JUN 18 P 2:33
 STATE ENGINEERS OF NV