WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43517
Permit No.
Basin 08-105

NOTICE OF INTENT NO. 24573

1. OWNER DANNY EDMONSON
MAILING ADDRESS LA, CALIF
ADDRESS AT WELL LOCATION 1895 ARABIAN GARDNERVILLE

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 29-511-02 (Parcel No.) RHUENSTROTH (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sandy clay		2	30	28
Cobbles, gravel sandy clay		30	42	12
Sandy clay		42	45	3
cobbles & gravel		45	60	15
Sandy clay		60	62	2
cobbles gravel sandy clay		62	66	4
Sandy clay		66	83	17
cemented gravel		83	102	19
gravel w sandy clay		102	110	8
Sandy clay		110	123	13
gravel w sandy clay	X	123	138	15
gravel w Short clay strks	XXX	138	160	22

'94 JAN 18 P2:33
RECEIVED
STATE ENGINEERS OFFICE

Date started 1-5, 1994
Date completed 1-10, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	25+		1

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	160

Perforations:
Type perforation Factory Slotted
Size perforation 3x3/32 Tourch cut
From ~~160~~ feet to ~~140~~ feet
From 140 feet to 160 feet
From T.C. 120 feet to 140 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 68' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W Phinnell (By driller performing actual drilling on site or contractor)
Date 1-10-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627