

OFFICE USE ONLY
 Log No. 73516
 Permit No. 8-105
 Basin 8-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24276

1. OWNER CLARK BUSH ADDRESS AT WELL LOCATION 2370 JACOBSEN GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SE 1/4 NE 1/4 Sec 5 T. 12 N. R. 21 E. DOUGLAS County DOUGLAS
 PERMIT NO. 35-140-22 Subdivision Name FISH SPRINGS
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand		0	2	2
sandy clay		2	14	12
cemented cobbles		14	23	9
course sand w clay		23	35	12
cemented cobbles		35	40	5
gravel w sandy clay		40	60	20
cobbles w some sandy clay		60	83	23
sandy clay		83	87	4
large gravel some clay		87	102	15
sandy clay		102	105	3
cobbles w sandy clay		105	117	12
cemented gravel		117	125	8
gravel some sandy clay	XR	125	153	28
cemented gravel	R	153	173	20
sandy clay w course sand		173	217	44
gravel some sandy clay	KXA	217	228	11
sandy clay		228	230	2

8. WELL CONSTRUCTION
 Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 5/8</u> Inches	<u>0</u> Feet <u>150</u> Feet
<u>5 5/8</u> Inches	<u>150</u> Feet <u>230</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>150</u>
<u>5</u>	<u>10</u>	<u>.188</u>	<u>150</u>	<u>230</u>

Perforations:
 Type perforation Factory Slotted / touch cut
 Size perforation 3.1/32 - 4 x 1/8
 From Factory 130 feet to 150 feet
 From T.G. 150 feet to 230 feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 150 feet

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Rhinard By driller performing actual drilling on site or contractor
 Date 12-22-93

Date started 12-15, 1993
 Date completed 12-21, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>		<u>4.5</u>

'94 JAN 18 P 2:33
 RECEIVED
 STATE ENGINEERS OFFICE