WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 23420

1. OWNER Joyce Gussenhoven
MAILING ADDRESS 30 Bumsteer Yerington, Nevada 89447
ADDRESS AT WELL LOCATION 30 Bumsteer Yerington, Nevada 89447

2. LOCATION SE ¼ SW ¼ Sec. 13 T. 12 N/S R. 25 E. Lyon County
PERMIT NO. N/A Issued by Water Resources
12-311-12 Parcel No.
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Sand		0	3	3
Tan clay		3	16	13
Tan clay and Sand		16	35	19
Broken Granet		35	115	80
Fractured Granet	✓	115	140	25

'94 JAN 18 P2:34 RECEIVED STATE ENGINEERS OFFICE

Date started 10-20, 1993
Date completed 11-19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 3 Hours produced about 35 Gallons a min		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15.00	3/16	+1	140

Perforations:
Type perforation Factory Perf
Size perforation 3/16 x 1 x 5 Rows x 20
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address PO Box 599 Silver Springs NV 89429 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-10-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627