WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43520
Permit No.
Basin 13-2017

NOTICE OF INTENT NO. 13236

1. OWNER Larry E. Peck
MAILING ADDRESS HC 34 Box 34125 Ely NV 89301
ADDRESS AT WELL LOCATION Main St. Preston

2. LOCATION SE ¼ SE ¼ Sec. 12 T. 12 N/S R. 61 E. White Pine County
PERMIT NO. NA (Issued by Water Resources) 11-450-04 (Parcel No.) Preston Townsite map (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1.5	
gravel-Cobbles		1.5	3	
Sandy clay		3	6	
Cobbles		6	8	
gravely clay		8	12	
Sandy clay		12	18	
gravel conglomerate		18	38	
clay		38	44	
gravel con.		44	46	
clay		46	52	
cemented gravel con		52	84	
Sand gravel	water	84	97	
clay		97	100	
Sand gravel	water	100	105	
clay		105	110	
gravel	water	110	113	
clay		113	115	
gravel	water	115	120	

Date started Jan 10, 1994
Date completed Jan 21, 1994

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	2	1 hr

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	50
8	50	120

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	120

Perforations:
Type perforation mill
Size perforation 1 x 2.5 x 6 row
From feet to feet
From 78 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 5 to 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 77 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature mid 60 F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address PO Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orson Maynard (By driller performing actual drilling on site or contractor)
Date Jan 24-94

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627