WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43523
Permit No.
Basin 08-105

NOTICE OF INTENT NO. 24274

1. OWNER CONSTRUCTION ZONE
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1915 WILD ONION GARDNERVILLE

2. LOCATION SW ¼ SE ¼ Sec. 36 T. 13 N/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-472-51 (Parcel No.) WILDFLOWER (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/GRAVEL		0	13	13
CEMENTED SAND + GRAVEL		13	34	21
SANDY CLAY w/GRAVEL		34	73	39
CLAY		73	81	8
SANDY CLAY		81	149	68
CLAY		149	178	29
FRACTURED BASALT		178	199	21
GRAY SANDY CLAY		199	280	81
CEMENTED GRAVEL		280	292	12
CLAY + SANDY CLAY		292	602	310
SAND	✓	602	605	3
SANDY CLAY		605	616	11
SAND + GRAVEL	✓	616	619	3
SANDY CLAY		619	621	2
SAND	✓	621	623	2
SANDY CLAY		623	630	7
SAND + GRAVEL	✓	630	633	3
SANDY CLAY		633	640	7

'94 JAN 18 P2:32 STATE ENGINEERS

Date started 12/21, 1993
Date completed 1/, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	4

8. WELL CONSTRUCTION
Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	640 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	640

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 600 feet to 640 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 640 feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature warm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27613

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Patl J. Moore
By driller performing actual drilling on site or contractor

Date 1-10-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627