

Log No. 43530
 Permit No. 8-1041103
 Basin 8-1041103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25288

1. OWNER Russell & Lita Henry ADDRESS AT WELL LOCATION 5989 Mallow Rd Carson City NV 89704
 MAILING ADDRESS 5989 Mallow Rd Carson City NV 89704 P.O. Box 2186 CC 89702
 2. LOCATION SW 1/4 NE 1/4 Sec 23 T 15 S R 20 E Carson County
 PERMIT NO. 10-093-02 Parcel No. Dear Run Sub-Pinion Hills
 Issued by Water Resources Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Course Sands		3	27	24
Volcanic Sands		27	63	36
Course Clay Zone Brown		63	84	21
Volcanic Sands w/ Clay Seams		84	125	41
Brown Clay		125	130	5
HARD Volcanic Gravels		130	160	30

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 160 Feet
 From 0 Feet To 160 Feet
 From 0 Feet To 160 Feet
 From 0 Feet To 160 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation M. 11 slot
 Size perforation 3/32
 From 140 feet to 160 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 35 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 35 feet to 160 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow 20+ G.P.M. 20+ P.S.I.
 Water temperature 104 °F Quality Good

Date started 12/28, 1993
 Date completed 12/30, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>15</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Michael J. Haek
 Address 220750
 Nevada contractor's license number 31839
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1985
 Signed Michael J. Haek
 By driller performing actual drilling on site or contractor
 Date 12-30-93