WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43532
Permit No. 58739
Basin 06-089
NOTICE OF INTENT NO. 25287

1. OWNER Rich & Shar Mason
MAILING ADDRESS 5360 FrankTown Rd. Carson City NV. 89706
ADDRESS AT WELL LOCATION 5360 FrankTown Rd Carson City NV. 89706

2. LOCATION SW ¼ NW ¼ Sec. 310 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. SW4 SW4 (Issued by Water Resources) 55-060-20 (Parcel No.) FrankTown Ranchas (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburdan		0	3	3
Clay (Brown)		3	27	24
DG Course Sands		27	53	26
Hard pack Clay		53	114	61
DG Sands w/seams of Brown clay.		114	207	93
Blue Granite HARD		207	255	48
Course Broken Granite W/DG Sands.	XXX	255	300	45

Date started 1-10 1994
Date completed 1-31 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	110	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300'

Perforations:
Type perforation Mill Slot
Size perforation 3/32
From 260 feet to 300' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 300' feet

9. WATER LEVEL
Static water level 35' feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO (Contractor)
Address 5551 Hwy. 50 East Carson City, Nevada 8 (Contractor)
883-0459 - 883-
885-1889
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 1-31-94

FEB -2 AM 10:18
RECEIVED STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627