

OFFICE USE ONLY
 Log No. 43537
 Permit No. 9-179
 Basin 9-179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19847

1. OWNER Allyn Goodrich ADDRESS AT WELL LOCATION 1 1/2 miles south of Ely
 MAILING ADDRESS P.O. Box 150333
E. Ely, NV 89315
 2. LOCATION SW 1/4 NE 1/4 Sec. 27 T. 16 N. R. 63 E. White Pine County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Sand and Small Gravel		5	60	55
Clay and Small Gravel		60	80	20
Clay and Course Gravel		80	110	30
Clay and Small Gravel		110	190	80
Brown Clay		190	260	70
Clay & Small Gravel Water Bearing Stringers	x	260	280	20
Brown Clay		280	330	50
Clay and Small Gravel		330	340	10
Sand & Small Gravel Water Bearing Stringers	x	340	350	10
Clay and Small Gravel		350	360	10
Brown Clay		360	365	5

8. WELL CONSTRUCTION
 Depth Drilled 365 Feet Depth Cased 365 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 365 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	365

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 8 rows
 From 203 feet to 365 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 365 feet

9. WATER LEVEL
 Static water level 270 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue, Ely, NV 89301 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rick Lewis By Harold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date January 19, 1994

Date started 94 December 13, 19 93
 Date completed December 20, 19 93

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
3 H.P. 3600 Pump Set @336 Ft	25	20	4

94 JAN 25 P 2:24
 ENGINEERS OFFICE