Washoe Permit #4880

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43548
Permit No.
Basin 06-089

NOTICE OF INTENT NO. 24472

1. OWNER Barry Brandt
MAILING ADDRESS 9200 S. Virginia St. Reno NV 89511
ADDRESS AT WELL LOCATION 45 Middlefield PL. Old Washoe City NV. 89704

2. LOCATION SW ¼ NW ¼ Sec. 24 T. 17 N S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 50-220-54 (Parcel No.) Old Washoe City (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	4	4
Brown Sands		4	20	16
DG Sands Course		20	64	44
Silty Gray Clays		65	100	35
Green & White DG Sands with small Clay Balls		100	120	20

'94 JAN 20 P2:26
STATE ENGINEERS

Date started 12-29, 1993
Date completed 1-3, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	120

Perforations:
Type perforation Mill Slot
Size perforation 3/32
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 120' feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H [illegible] Contractor
Address [illegible] Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 1-3-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627