WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43553
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 23992

1. OWNER Jay Van Sickle
MAILING ADDRESS 151 South Rainbow Dr.
Dayton, Nevada 89403

ADDRESS AT WELL LOCATION 151 South Rainbow Dr.
Dayton, Nevada 89403

2. LOCATION N W ¼ SE ¼ Sec. 5 T. 17 N/S R. ~~22~~ E Lyon County

PERMIT NO. — Issued by Water Resources | 19-231-04 Parcel No. | — Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine To coarse Sand		0	75	75
Hard Red volcanic Rock		75	100	25
Hard Fractured gray+white granite	X	100	150	50

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	100	Feet
7⅞	Inches	100	Feet	150	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝		.188	+1	100
6⅝		.188	90	150

Perforations:
Type perforation MILL
Size perforation 18 X 3
From 80 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling + Development (Contractor)
Address P.O. Box 668 (Contractor)
Silver Springs, Nevada 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed H. L. [illegible] Jr. (By driller performing actual drilling on site or contractor)
Date 1-8-1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	45	2 hrs.

Date started 12-20, 1993
Date completed 12-28, 1993

'94 JAN 11 A10:09 RECEIVED STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627