

OFFICE USE ONLY
 Log No. 413558
 Permit No. _____
 Basin 08-162
 NOTICE OF INTENT NO. 23427

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Floyd Divine ADDRESS AT WELL LOCATION 5080 White Oak
 MAILING ADDRESS P.O. Box 1015
Silver Springs, NV. 89429
 2. LOCATION NE 1/4 N60 1/4 Sec. 1 T 17 N/S R 24 E Lyons County
 PERMIT NO. N/A 17-031-10 Churchill Estates Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand, Hardpan</u>		<u>1</u>	<u>4</u>	<u>4'</u>
<u>Sand, Gravel</u>		<u>4</u>	<u>20</u>	<u>16'</u>
<u>Clay</u>		<u>20</u>	<u>48</u>	<u>28</u>
<u>Clay Sand</u>		<u>48</u>	<u>60</u>	<u>12</u>
<u>Clay</u>		<u>60</u>	<u>72</u>	<u>12</u>
<u>Coarse Sand</u>	<u>72</u>	<u>72</u>	<u>101</u>	<u>31</u>
<u>Coarse Gravel</u>	<u>111</u>	<u>101</u>	<u>111</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 111 Feet Depth Cased 112 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 11 1/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/8</u>	<u>13</u>	<u>1.88</u>	<u>+1</u>	<u>111</u>

Perforations:
 Type perforation mill perf
 Size perforation 2 1/2 x 3 x 6 mm perf
 From 39 feet to 111 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 111 feet

9. WATER LEVEL
 Static water level 69 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature W °F Quality Good

Date started 12/31/93 19____
 Date completed 1/11/94 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30-35</u>		<u>3 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Geach Drilling Inc
 Address PO 599 S.S.
Nv. 89429
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed Daniel Geach
 By driller performing actual drilling on site or contractor
 Date 1/3/94