WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43559
Permit No.
Basin 08-102

NOTICE OF INTENT NO. 23428

1. OWNER Manderville, Wayne
MAILING ADDRESS 2910 Holly St. Silver Springs, NV. 89429
ADDRESS AT WELL LOCATION 2910 Holly Street Silver Springs, Nevada

2. LOCATION SW ¼ SE ¼ Sec. 5 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. [redacted] N/A (Issued by Water Resources) 17-116-07 (Parcel No.) Lakeview Sub 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	9	9'
Sand, Clay		9	21	12'
Clay		20	36	16'
Sand		36	43	7'
Clay (Biege)		43	62	19'
Clay (Grey)		62	90	18'
Sand, Clay		90	120	30'
Decomposed granite	124	120	139	19'
(Broken)	139			

'94 JAN 18 P2:21
STATE ENGINEERS OFFICE

Date started 12/29/93, 19
Date completed 1/16/, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45 gpm		2½ hrs

8. WELL CONSTRUCTION
Depth Drilled 139 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 11 Feet To 139 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	+1	139

Perforations:
Type perforation Mill Perf
Size perforation 3/16 x 3 x 6 rows perf
From 119 feet to 139 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 139 feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address P.O. 299 (Contractor)
S.S. NV, 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Daniel Leach
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627