WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 43561
Permit No.
Basin 08-102

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 20239

1. OWNER John Hoden
MAILING ADDRESS P.O. Box 53
Silver Springs, Nv

ADDRESS AT WELL LOCATION
2535 4th St
Silver Springs, Nv 89429

2. LOCATION SW ¼ SE ¼ Sec. 8 T. 17 N S R. 25 E Lyon County
PERMIT NO. (Issued by Water Resources) 17-167-01 (Parcel No.) Putnam #2 Lot 49 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 6" | 6" |
| Clay | | 6" | 3' | 2½' |
| Sand & Clay | | 3' | 18' | 15' |
| Clay | | 18' | 36' | 18' |
| Course Sand & gravel | | 36 | 49' | 13' |
| Clay | | 49' | 54' | 5' |
| Sand | | 54' | 56' | 2' |
| Brown Clay | | 56' | 60' | 4' |
| fine sand (quick) | | 60' | 80' | 20' |
| Clay | | 80' | 84' | 4' |
| Quick sand | | 84' | 122' | 38' |
| Brown clay | | 122' | 124' | 2' |
| Course Sand & Gravel | X | 124' | 132' | 8' |
| Clay | | 132' | 134' | 2' |

JAN 13 '94 A11 26
STATE ENGINEER'S OFFICE

Date started 12/10, 1993
Date completed 1/3, 1994

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| 3450 | 19½ | 5 | 4 |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 134 feet
..... inches
..... inches
Casing record
Weight per foot 13.77 Thickness .188

| Diameter | From | To |
|---|---|---|
| 10 inches | 0 feet | 53 feet |
| 6 inches | 0 feet | 134 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 53' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 1/8 x 3
From 132 feet to 124 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Cannon Jr. (Contractor)
Address 4555 Hwy 50 W Silver Springs, Nv (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada contractor's driller's number issued by the Division of Water Resources 1455
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr. (By driller performing actual drilling on site or contractor)
Date 1/4/94

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627