

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23879

1. OWNER Bill Dinkins ADDRESS AT WELL LOCATION #11 Lockwood Dr
 MAILING ADDRESS 5600 High Rock Way
Sparks, Nv 89431

2. LOCATION NE 1/4 SE 1/4 Sec. 17 T. 19 N/S R. 21 E Washoe County
 PERMIT NO. 5F 084-080-37 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles & boulders		0	17	17
Reddish brown & green clay with green yellow brown sands & gravels		17	24	7
Red clay with traces of green gravels		24	37	13
Green coarse gravels with scattered boulders		37	98	61
Green & gray clay with red & green gravels		98	114	16
Green coarse gravels with green & gray clay		114	123	9
Light green clay		123	154	31
Reddish brown clay with red & green gravels		154	205	51
Sticky red clay		205	223	18
Light green clay & sands		223	246	23
Sticky red clay		246	291	45
Green & white rock hard with red specs		291	562	271
T.D. 562				

8. WELL CONSTRUCTION
 Depth Drilled 562 Feet Depth Cased 562 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0	290
8 1/2 Inches	290	320
6 Inches	320	562

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	320
5	9.62	.188	302	562

Perforations: factory
 Type perforation
 Size perforation 3/32 X 3

From 300 feet to 320 feet
 From 542 feet to 562 feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 101 ft Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 101 feet to 320 feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature warm °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Roger M. Thrall 12/17/93
 Date 12/17/93

Date started 12/7/93, 19...
 Date completed 12/16/93, 19...

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3 1/2</u>		<u>2</u>